



Jones Gillam Renz Architects

Address

730 N 9th St.
Salina, KS 67401

1881 Main St., Suite 301
Kansas City, MO 64108

Contact

jgr@jgrarchitects.com
(785) 827-0386

Web

jgrarchitects.com

NOTICE TO ALL CONTRACTORS AND SUB-CONTRACTORS

January 9, 2025

USD 307 Ell-Saline Secure Entries – JGR Proj 24-3432

Prebid Meeting Date: Wednesday, January 8, 2025 at 4:00 p.m. JR.-SR. Library, 412 E. Anderson Road, Brookville, KS.

Bid Date: Friday, January 10, 2025 at 2:00 p.m., Ell-Saline District Office, 412 E. Anderson Road, Brookville, KS.

ADDENDUM NO. 2

YOU ARE INSTRUCTED TO READ AND TO NOTE THE FOLLOWING DESCRIBED CHANGES, CORRECTIONS, CLARIFICATIONS, OMISSIONS, DELETIONS, ADDITIONS, APPROVALS, AND STATEMENTS PERTINENT TO THE CONTRACT AND CONSTRUCTION DOCUMENTS. THIS ADDENDUM IS A PART OF THE CONTRACT AND CONSTRUCTION DOCUMENTS AND SHALL GOVERN IN THE PERFORMANCE OF THE WORK.

GENERAL

1. Reference attached list of Prebid Attendees.

ARCHITECTURAL – Specifications

1. Section 08111 Standard Steel Doors and Frames, paragraph 2.01E - CECO Doors (and frames) as well as Mesker Door Inc., are approved as equivalent.
2. Section 08410 Aluminum Entrances and Storefronts, paragraphs 2.02D, 2.03C, 2.04B – Fire-rated aluminum doors and fire-rated aluminum frames have been eliminated.

ARCHITECTURAL – Drawings

1. Sheet A3.1 –
 - A. Door Types – Eliminate Aluminum from Door Type B.
 - B. Door Types – Add Solid Core Wood Door (Rotary Select White Birch, field finished) for Door Type B. Door to be as per Masonite or equivalent.
 - C. Door Schedule – Door H102 shall be changed to a Solid Core Wood Door (20-minute fire-rated) with rated hollow metal frame.

Receipt of this Addendum shall be noted on the Bid Form.

END OF ADDENDUM NO. 2

Attachments
Prebid Attendees – 1pg.

