



Jones Gillam Renz Architects

Address

730 N 9th St.
Salina, KS 67401

1881 Main St., Suite 301
Kansas City, MO 64108

Contact

jgr@jgrarchitects.com
(785) 827-0386

Web

jgrarchitects.com

NOTICE TO ALL CONTRACTORS AND SUB-CONTRACTORS

9-3-2025

The Temple – Elevator Rehabilitation Project – JGR Proj. 25-3499

ADDENDUM NO. 2

YOU ARE INSTRUCTED TO READ AND TO NOTE THE FOLLOWING DESCRIBED CHANGES, CORRECTIONS, CLARIFICATIONS, OMISSIONS, DELETIONS, ADDITIONS, APPROVALS, AND STATEMENTS PERTINENT TO THE CONTRACT AND CONSTRUCTION DOCUMENTS. THIS ADDENDUM IS A PART OF THE CONTRACT AND CONSTRUCTION DOCUMENTS AND SHALL GOVERN IN THE PERFORMANCE OF THE WORK.

ELECTRICAL/PLUMBING – Drawings

1. Sheet E0.1 – Updated Fire Alarm specification to remove requirement for monitoring.
2. Sheet E1.1
 - a. Removed smoke detector from elevator pit
 - b. Relocated fire alarm control panel to lower level elevator lobby.
 - c. Removed smoke detector from top of elevator hoistway.
3. Sheet E6.1 – Modified Elevator interlock with fire alarm detail
4. Sheet E6.2 – Modified panel schedules for panelboards 'L01' and 'L71'.

Receipt of this Addendum shall be noted on the Bid Form.

END OF ADDENDUM NO. 2

Attachments – Full Revised Set.