



Jones Gillam Renz Architects

Address

730 N 9th St.
Salina, KS 67401

1881 Main St., Suite 301
Kansas City, MO 64108

Contact

jgr@jgrarchitects.com
(785) 827-0386

Web

jgrarchitects.com

NOTICE TO ALL CONTRACTORS AND SUB-CONTRACTORS

October 1, 2026

USD 305 Central High – Window Replacement – JGR Proj #25-3504

Bid Date: Tuesday, October 6, 2026 at Board Office Conference Room, 1511 Gypsum Ave, Salina, KS by 2:30 p.m.

ADDENDUM NO. 1

YOU ARE INSTRUCTED TO READ AND TO NOTE THE FOLLOWING DESCRIBED CHANGES, CORRECTIONS, CLARIFICATIONS, OMISSIONS, DELETIONS, ADDITIONS, APPROVALS, AND STATEMENTS PERTINENT TO THE CONTRACT AND CONSTRUCTION DOCUMENTS. THIS ADDENDUM IS A PART OF THE CONTRACT AND CONSTRUCTION DOCUMENTS AND SHALL GOVERN IN THE PERFORMANCE OF THE WORK.

GENERAL

1. Reference attached list of Prebid Attendees.

ARCHITECTURAL – Drawings

1. Sheet A1, Exterior Elevation C – Window Types are listed incorrectly. Correct listing is:
 - A. Type 1 Window Units shall be "A".
 - B. Type 2 Window Unit shall be "B".
 - C. Type 3 Window Units shall be "C".
 - D. Type 4 Window Units shall be "D".
2. Sheet A3, Wall Sections C and D – At Storage #104 and Classroom #105 window opening head locations; provide and install 24 ga. prefinished white aluminum metal (approximately 20" tall) fastened to interior face of masonry wall and dropped down vertically with 1" horizontal leg for existing acoustical tiles to sit. Overlap metal pieces approximately 1" and fasten with prefinished white pop rivets. Hem all exposed edges. Cut existing acoustical tiles at window locations and reinstall.
3. Sheet A4, Window Head Detail H – At Type C Window Units, provide and install continuous pressure treated wood blocking above window unit head (approximately 2" thickness) and wrap with prefinished metal. Coordinate with window installer to ensure watertight condition.

Receipt of this Addendum shall be noted on the Bid Form.

END OF ADDENDUM NO. 1

Attachments

Prebid Attendees – 1pg.



730 N. 9th St., Salina KS 67401
1881 Main St, Ste 301,
Kansas City, MO 64108
785 827 0386

**USD 305 Salina School District
Window Replacement
Salina Central High School
650 E. Crawford, Salina, KS**

Prebid Meeting – 3 pm – September 29, 2026
JGR Project 25-3504

[illegible]